

EU TYPE-EXAMINATION CERTIFICATE (MODULE B) REGULATION (EU) 2016/426

This is to certify that the appliances listed have been examined and found to comply with the essential requirements listed in the **Regulation (EU) 2016/426** of the European Parliament and of the council of 9 March 2016 on appliances burning gaseous fuels (Annex I).

To demonstrate full compliance with the Regulation (EU) 2016/426, a "Conformity to Type" Module C2 or D or E or F is required.

Applicant: Immergas S.p.A.
Via Cisa Ligure, 95, 42041 Brescello (RE)

Trade Mark: IMMERGAS

Product Type: Central heating condensing boiler

Models: VICTRIX PLUS 24 HY; VICTRIX 24 HY

Certificate N°: ITS-2575-GAR-212965405

PIN: 2575DM296541

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200029654UDI-GCEa-RCE



Certificate Issue date:

06 September 2021

Certificate Expiry date:

05 September 2031

Gino Baiocco

Certification Officer
Intertek Italia SpA (NB 2575)



PDR N° 277B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

PRODUCT DESCRIPTION

PRODUCT TYPE:	Central heating condensing boiler
MODELS:	VICTRIX PLUS 24 HY; VICTRIX 24 HY
STANDARD(S):	EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016
SPECIAL REMARKS:	-
APPLIANCES TYPE:	C ₁₃ , C _{13x} , C ₃₃ , C _{33x} , C ₄₃ , C _{43x} , C ₅₃ , C ₆₃ , C ₈₃ , C _{83x} , C ₉₃ , C _{93x} , B ₂₃ , B ₃₃ , B _{53P}

The gas categories for which the appliances have been tested can be obtained by combining the following countries and gas groups:

COUNTRIES: BG, CZ, ES, GR, HR, HU, IE, IT, PL, PT, RO, SI, SK

GAS GROUP, REFERENCE GAS AND SUPPLY PRESSURES:

GROUP	REFERENCE GAS	GROUP	REFERENCE GAS	GROUP	REFERENCE GAS
H	G20 – 20 mbar	M	G230 – 20 mbar	P	G31 – 37 mbar
H	G20 – 25 mbar				

REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PRJ NO.	REPORT NO.	REASON FOR REVISION
06/09/2021	G. Baiocco	29654	200029654UDI-GCEa-RCE	R0: First issue