

IT

**KIT VALVOLA DI NON RITORNO SUI FUMI
VICTRIX TERA V2
COD. 3.032877**

AVVERTENZE GENERALI.

Tutti i prodotti sono protetti con idoneo imballaggio da trasporto. Il materiale deve essere immagazzinato in ambienti asciutti ed al riparo dalle intemperie.

Il presente foglio istruzioni contiene informazioni tecniche relative all'installazione del kit. Per quanto concerne le altre tematiche correlate all'installazione del kit stesso (a titolo esemplificativo: sicurezza sui luoghi di lavoro, salvaguardia dell'ambiente, prevenzioni degli infortuni), è necessario rispettare i dettami della normativa vigente ed i principi della buona tecnica.

L'installazione o il montaggio improprio dell'apparecchio e/o dei componenti, accessori, kit e dispositivi potrebbe dare luogo a problematiche non prevedibili a priori nei confronti di persone, animali, cose. Leggere attentamente le istruzioni a corredo del prodotto per una corretta installazione dello stesso.

L'installazione e la manutenzione devono essere effettuate in ottemperanza alle normative vigenti, secondo le istruzioni del costruttore e da parte di personale abilitato nonché professionalmente qualificato, intendendo per tale quello avente specifica competenza tecnica nel settore degli impianti, come previsto dalla Legge.

ATTENZIONE.

Questo kit è abbinabile alle caldaie a condensazione IMMERGAS della gamma Victrix Tera V2.

Il kit è installabile solamente con fumisteria concentrica Ø80/125 o con fumisteria sdoppiata Ø80/80, nelle configurazioni che prevedono l'innesto in canna fumaria collettiva C₍₁₀₎ - C₍₁₂₎.

Questo kit deve essere necessariamente abbinato a fumisteria originale Immergas "Serie Verde".

INSTALLAZIONE.

Per l'installazione del presente kit fare riferimento al libretto istruzioni di caldaia.

IE

**FLUE NON-RETURN VALVE KIT
VICTRIX TERA V2
COD. 3.032877**

GENERAL WARNINGS.

All products are protected with suitable transport packaging. The material must be stored in dry environments and protected against weathering.

This instruction manual provides technical information for installing the kit. As for the other issues related to kit installation (e.g. safety in the work site, environment protection, injury prevention), it is necessary to comply with the provisions specified in the regulations in force and principles of good practice.

Improper installation or assembly of the appliance and/or components, accessories, kit and devices can cause unexpected problems to people, animals and objects. Read the instructions provided with the product carefully to ensure a proper installation.

Installation and maintenance must be performed in compliance with the regulations in force, according to the manufacturer's instructions and by authorised professionally qualified staff, intending staff with specific technical skills in the plant sector, as envisioned by the Law.

ATTENTION.

This kit must be combined with IMMERGAS condensing boilers of the Victrix Tera V2 range.

The kit can be installed only with concentric flue Ø80/125 or with split flue Ø80/80, in the configurations that require the connection in the collective flue C₍₁₀₎ - C₍₁₂₎.

This kit must necessarily be combined with the original Immergas "Green Series" flue system.

INSTALLATION.

For the installation of this kit, refer to the boiler instructions booklet.