


CERTIFICATE

Certificate holder	Immergas S.p.a. Via Cisa Ligure 95 42041 Brescello RE ITALY
Production facility	St. Veit
Product	Solar collectors
Type, Model	Collettore Solar Piano CP 4M
Testing basis	DIN EN 12975-1:2011-01 DIN EN ISO 9806:2018-04 SOLAR KEYMARK Scheme Rules (2021-07)
Mark of conformity	
Registration No.	011-7S1756 F
Valid until	2026-11-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Page 1 of 1

Certificate

011-7S1756 F dated 2022-07-05

Technical Data

See data sheet, part of the test report of 2022-06-08

Note(s):

- The freeze resistance test according to DIN EN ISO 9806, clause 14 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures or with appropriate frost protection controller.

**Testing laboratory/
Inspection body**

Universität Stuttgart
Institut für Gebäudeenergetik,
Thermotechnik und Energie-
speicherung
Pfaffenwaldring 6-6 a
70569 Stuttgart
GERMANY

Test report(s)

20COL1537/10EM06, 20COL1538Q/20EM06 dated 2022-06-08

