

Number	KIP-08116	Replaces	KIP-17315/G
Issue date	27-10-2025	Contract number	6700
Due date	26-10-2035	Scope	(EU) 2016/426 (9 March 2016)
Report number	2011142/2	Module	B (Type testing)
PIN	0476DN1142		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**VICTRIX SUPERIOR 26, VICTRIX SUPERIOR 35, VICTRIX SUPERIOR 35 PLUS,
UCI EUREKA 26, UCI EUREKA 35**

Manufacturer

IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041, Brescello (RE), Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard:

EN 15502-1:2021+A1:2023

EN 15502-2-1:2022+A1:2023, EN 15502-2-1:2022+A1:2023/AC:2024

CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428
E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Luigi Rindone

Firmato digitalmente da:

Luigi Rindone

Firmato il 27/10/2025

17:27

Seriale Certificato:

4208672490484958826

Valido dal 15/10/2025

al 14/10/2028

UANATACA Qualified

eIDAS CA 2020



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number KIP-08116 **Page** 1 of 1
Issue date 27-10-2025 **Scope** (EU) 2016/426 (9 March 2016)
Due date 26-10-2035 **Module** B (Type testing)
Report number 2011142/2
PIN 0476DN1142

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name: **IMMERGAS**

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX SUPERIOR 26, UCI EUREKA 26	24,7 – 2,2	26,0 – 2,2
VICTRIX SUPERIOR 35, UCI EUREKA 35	32,8 – 2,2	34,0 – 2,2
VICTRIX SUPERIOR 35 PLUS	32,8 – 2,2	34,0 – 2,2

Appliance types:

B_{23P}, B₃₃, B_{33P}, B₅₃, B_{53P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃,
 C₍₁₀₎₃, C₍₁₂₎₃, C₍₁₅₎₃, C_{13X}, C_{33X}, C_{43X}, C_{53X}, C_{63X}, C_{83X}, C_{93X}
 C_{(10)3X}, C_{(12)3X}, C_{(15)3X}

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	E(S)	20	P	30; 37; 50
H	20; 25	Lw	20		
EY20 ⁽¹⁾	20	Ls	13		
HY20 ⁽¹⁾	20;25	M	20		
NY20Z192 ^{(1) (2)}	20				

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note:


⁽¹⁾ "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H₂) when the appliance is set for the reference gas G₂₀.

⁽²⁾ Suffix "Z92" indicates a Wobbe bandwidth of 19,2 MJ/m³. This means that the appliances are suitable for the use of natural gas of the gas groups E – H - Lw, with a Wobbe range between 35,5 MJ/m³ and 54,69 MJ/m³.

Remarks: –

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and /or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-08117	Replaces	KIP-17315/E
Issue date	27-10-2025	Contract number	6700
Report number	2011142/2	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476DN1142	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boilers, type(s):

**VICTRIX SUPERIOR 26, VICTRIX SUPERIOR 35, VICTRIX SUPERIOR 35 PLUS,
UCI EUREKA 26, UCI EUREKA 35**

Manufacturer

IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041, Brescello (RE), Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard:

EN 15502-1:2021+A1:2023

EN 15502-2-1:2022+A1:2023, EN 15502-2-1:2022+A1:2023/AC:2024

CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta
all'attività di direzione e coordinamento
di Kiwa Italia Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale
Via Treviso 32/34
31020 San Vendemiano (TV)
Tel +39. 0438 411755
Fax +39.0438 22428

E-mail: info@kiwacermet.it
www.kiwa.it

Organismo Notificato n. 0476
Notified Body nr. 0476

Industry Division Manager
Luigi Rindone

Firmato digitalmente da:
Luigi Rindone
Firmato il 27/10/2025 17:36
Seriale Certificato: 4208672490484958826
Valido dal 15/10/2025 al 14/10/2028
UANATACA Qualified eIDAS CA 2020



PRD N° 0069PRD

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements

Number	KIP-08117	Page	1 of 3
Issue date	27-10-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011142/2	Module	B (Type testing)
PIN	0476DN1142		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):
VICTRIX SUPERIOR 26, UCI EUREKA 26

Condensing boiler:		yes
Range rated:	yes	
Low-temperature boiler:		no
B1 boiler:	no	
Combination heater:	yes	

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,1	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,1	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,1	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,7	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-08117	Page	2 of 3
Issue date	27-10-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011142/2	Module	B (Type testing)
PIN	0476DN1142		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):

VICTRIX SUPERIOR 35, UCI EUREKA 35

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,7	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,6	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-08117	Page	3 of 3
Issue date	27-10-2025	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011142/2	Module	B (Type testing)
PIN	0476DN1142		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):
VICTRIX SUPERIOR 35 PLUS

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	87,8	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,7	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	97,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,6	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.