

## Certificate KIP-08286



Issue date	12-05-2026	Replaces	KIP-07618
PIN	0476CT2311	Report number	2002311/4
Valid from	12-05-2026	Due date	11-05-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

## EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**VICTRIX OMNIA  
VICTRIX OMNIA 25**

**Manufacturer**

**IMMERGAS EUROPE S.r.o**  
**Priemyselna Ulica 4789**  
**SK-05951 Poprad Metejevce, Slovakia**

Meet the essential requirements as described in the  
**Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Reference standard:  
EN 15502-1:2021+A1:2023  
EN 15502-2-1:2022+A1:2023  
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.A.  
Product Certification and Testing Director da:  
Luigi Rindone

Firmato digitalmente da:  
Luigi Rindone

# Certificate

## KIP-08286

Issue date	12-05-2026	Replaces	KIP-07618
PIN	0476CT2311	Report number	2002311/4
Valid from	12-05-2026	Due date	11-05-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

### APPENDIX TO EU TYPE- EXAMINATION CERTIFICATE (GAR)

Brand name:

IMMERGAS

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX OMNIA	20,8 – 4,2	25,7 – 4,2
VICTRIX OMNIA 25	20,8 – 4,2	25,7 – 4,2

Appliance types:

B<sub>23</sub>, B<sub>23P</sub>, B<sub>53</sub>, B<sub>53P</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>, C<sub>93</sub>  
C<sub>13x</sub>, C<sub>33x</sub>, C<sub>43x</sub>, C<sub>93x</sub>

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	Esi	20/25	Lw	20
H	20; 25	E(S)	20	P	37
EY20	20	Er	20/25		
HY20	20; 25	M	20		

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

**Note:** Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H<sub>2</sub>) when the appliance is set for the reference gas G20.

Remarks: -

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

## Certificate KIP-08287



Issue date	12-05-2026	Replaces	KIP-07619
PIN	0476CT2311	Report number	2002311/4
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

### EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boiler, type(s):

**VICTRIX OMNIA  
VICTRIX OMNIA 25**

**Manufacturer**

**IMMERGAS EUROPE S.r.o**

**Priemyselna Ulica 4789**

**SK-05951 Poprad Metejevce, Slovakia**

Meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements.**

Reference standard:  
EN 15502-1:2021+A1:2023  
EN 15502-2-1:2022+A1:2023  
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.a.  
Product Certification and Testing Director  
Luigi Rindone

Firmato  
digitalmente  
da:  
Luigi  
Rindone

# Certificate

## KIP-08287

Issue date	12-05-2026	Replaces	KIP-07619
PIN	0476CT2311	Report number	2002311/4
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

### APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:  
IMMERGAS

Specifications:

Model(s):  
VICTRIX OMNIA  
VICTRIX OMNIA 25

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P <sub>4</sub>	20,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P <sub>1</sub>	6,6	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	$\eta_4$	87,3	%
At 30 % of rated heat output and low-temperature regime (**)	$\eta_1$	96,2	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	$\eta_{100}$	96,9	%
At 30 % of rated heat output and low-temperature regime (**)	$\eta_{30}$	106,8	%

- (\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.