

## Certificate KIP-08268



|            |                  |               |                                   |
|------------|------------------|---------------|-----------------------------------|
| Issue date | 20-04-2026       | Replaces      | KIP-07614                         |
| PIN        | 0476DN1192       | Report number | 2011192/7                         |
| Valid from | 20-04-2026       | Due date      | 19-04-2036                        |
| Module     | B (Type testing) | Scope         | Reg. (EU) 2016/426 (9 March 2016) |

### EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**VICTRIX TERA 24 V2, VICTRIX TERA 24 PLUS V2,  
VICTRIX TERA V2 28 EU, VICTRIX TERA V2 24 PLUS EU,  
VICTRIX TERA 28 V2, VICTRIX TERA V2 32 EU,  
VICTRIX TERA V2 38 EU, VICTRIX TERA V2 35 PLUS EU**

Manufacturer

**IMMERGAS S.p.A.**  
**Via Cisa Ligure, 95**  
**42041, Brescello (RE), Italy**

Meet the essential requirements as described in the  
**Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.**

Reference standard:  
EN 15502-1:2021+A1:2023  
EN 15502-2-1:2022+A1:2023/AC:2024  
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

  
Kiwa Cermet Italia S.p.a.  
Product Certification and Testing Director  
Luigi Rindone

Firmato digitalmente da:  
Luigi Rindone

# Certificate

## KIP-08268

|            |                  |               |                                   |
|------------|------------------|---------------|-----------------------------------|
| Issue date | 20-04-2026       | Replaces      | KIP-07614                         |
| PIN        | 0476DN1192       | Report number | 2011192/7                         |
| Valid from | 20-04-2026       | Due date      | 19-04-2036                        |
| Module     | B (Type testing) | Scope         | Reg. (EU) 2016/426 (9 March 2016) |

### APPENDIX TO EU TYPE- EXAMINATION CERTIFICATE (GAR)

Brand name: **IMMERGAS**

| Model name                 | Heat Input (Hi)         |                          |
|----------------------------|-------------------------|--------------------------|
|                            | CH<br>Max – Min<br>(kW) | DHW<br>Max – Min<br>(kW) |
| VICTRIX TERA 24 V2         | 24,5 – 4,5              | 28,7 - 4,5               |
| VICTRIX TERA 24 PLUS V2    | 24,5 – 4,5              | 28,7 - 4,5               |
| VICTRIX TERA V2 28 EU      | 24,5 – 4,5              | 28,7 - 4,5               |
| VICTRIX TERA V2 24 PLUS EU | 24,5 – 4,5              | 28,7 - 4,5               |
| VICTRIX TERA 28 V2         | 28,6 - 5,0              | 32,7 - 5,0               |
| VICTRIX TERA V2 32 EU      | 28,6 - 5,0              | 32,7 - 5,0               |
| VICTRIX TERA V2 38 EU      | 32,8 - 6,3              | 38,3 - 6,3               |
| VICTRIX TERA V2 35 PLUS EU | 32,8 - 6,3              | 38,3 - 6,3               |

Appliance types:

B<sub>23</sub>, B<sub>23P</sub>, B<sub>33</sub>, B<sub>53</sub>, B<sub>53P</sub>, C<sub>13</sub>, C<sub>33</sub>, C<sub>43</sub>, C<sub>53</sub>, C<sub>63</sub>, C<sub>83</sub>, C<sub>93</sub>, C<sub>13X</sub>, C<sub>33X</sub>, C<sub>43X</sub>, C<sub>53X</sub>, C<sub>63X</sub>, C<sub>83X</sub>, C<sub>93X</sub>, C<sub>(15)3</sub>, C<sub>(10)3</sub><sup>\*</sup>, C<sub>(12)3</sub><sup>\*</sup>  
 \*: appliance type valid only for gas group H and E

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

# Certificate

## KIP-08268

|            |                  |               |                                   |
|------------|------------------|---------------|-----------------------------------|
| Issue date | 20-04-2026       | Replaces      | KIP-07614                         |
| PIN        | 0476DN1192       | Report number | 2011192/7                         |
| Valid from | 20-04-2026       | Due date      | 19-04-2036                        |
| Module     | B (Type testing) | Scope         | Reg. (EU) 2016/426 (9 March 2016) |

### APPENDIX TO EU TYPE- EXAMINATION CERTIFICATE (GAR)

Gas groups:

| Models                     | Gas groups<br>mbar | E  | H  | H  | EY20 | HY20 | HY20 | E(S) | M  | Lw | P  | P  |
|----------------------------|--------------------|----|----|----|------|------|------|------|----|----|----|----|
|                            |                    | 20 | 20 | 25 | 20   | 20   | 25   | 20   | 20 | 20 | 37 | 50 |
| VICTRIX TERA 24 V2         |                    | X  | X  | X  | X    | X    | X    | X    | X  | X  | X  | X  |
| VICTRIX TERA 24 PLUS V2    |                    | X  | X  | X  | X    | X    | X    | X    | X  | X  | X  | X  |
| VICTRIX TERA V2 28 EU      |                    | X  | X  | X  | X    | X    | X    | X    | X  | X  | X  | X  |
| VICTRIX TERA V2 24 PLUS EU |                    | X  | X  | X  | X    | X    | X    | X    | X  | X  | X  | X  |
| VICTRIX TERA 28 V2         |                    | X  | X  | X  | X    | X    | X    | X    | X  | X  | X  | X  |
| VICTRIX TERA V2 32 EU      |                    | X  | X  | X  | X    | X    | X    | X    | X  | X  | X  | X  |
| VICTRIX TERA V2 38 EU      |                    | X  | X  | X  | X    | X    | X    | X    |    | X  | X  | X  |
| VICTRIX TERA V2 35 PLUS EU |                    | X  | X  | X  | X    | X    | X    | X    |    | X  | X  | X  |

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

*Note:* Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H2) when the appliance is set for the reference gas G20.

Remarks: -

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Certificate  
**KIP-08269**



|            |                  |               |   |
|------------|------------------|---------------|---|
| Issue date | 20-04-2026       | Replaces      | KIP-07615   |
| PIN        | 0476DN1192       | Report number | 2011192/7   |
| Module     | B (Type testing) | Scope         | Art.4 of No.813/2013 (2-8-2013)<br>and 92/42/EEC (21-05-1992) |

## EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boiler, type(s):

VICTRIX TERA 24 V2, VICTRIX TERA 24 PLUS V2, VICTRIX TERA V2 28 EU,  
VICTRIX TERA V2 24 PLUS EU, VICTRIX TERA 28 V2, VICTRIX TERA V2 32 EU,  
VICTRIX TERA V2 38 EU, VICTRIX TERA V2 35 PLUS EU

**Manufacturer**  
**IMMERGAS S.p.A.**  
**Via Cisa Ligure, 95**  
**42041, Brescello (RE), Italy**

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements.**

Reference standard:  
EN 15502-1:2021+A1:2023  
EN 15502-2-1:2022+A1:2023/AC:2024  
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.a.  
Product Certification and Testing Director  
Luigi Rindone  
Firmato digitalmente da:  
Luigi Rindone

# Certificate

## KIP-08269

|            |                  |               |  |
|------------|------------------|---------------|--|
| Issue date | 20-04-2026       | Replaces      | KIP-07615  |
| PIN        | 0476DN1192       | Report number | 2011192/7  |
| Module     | B (Type testing) | Scope         | Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992) |

### APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):

VICTRIX TERA 24 V2, VICTRIX TERA V2 28 EU

|                         |     |
|-------------------------|-----|
| Condensing boiler:      | yes |
| Range rated:            | yes |
| Low-temperature boiler: | no  |
| B1 boiler:              | no  |
| Combination heater:     | yes |

Useful heat output

|  |                |         |
|--|----------------|---------|
| At rated heat output and high-temperature regime (*)         | P <sub>4</sub> | 24,0 kW |
| At 30 % of rated heat output and low-temperature regime (**) | P <sub>1</sub> | 8,0 kW  |

Useful efficiencies (GCV)

|  |          |        |
|--|----------|--------|
| At rated heat output and high-temperature regime (*)         | $\eta_4$ | 87,8 % |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_1$ | 98,7 % |

Useful efficiencies (NCV)

|  |              |         |
|--|--------------|---------|
| At rated heat output and high-temperature regime (*)         | $\eta_{100}$ | 97,5 %  |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_{30}$  | 109,6 % |

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

*The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)*

*This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.*

*Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.*

# Certificate

## KIP-08269

|            |                  |               |  |
|------------|------------------|---------------|--|
| Issue date | 20-04-2026       | Replaces      | KIP-07615  |
| PIN        | 0476DN1192       | Report number | 2011192/7  |
| Module     | B (Type testing) | Scope         | Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992) |

### APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):

VICTRIX TERA 28 V2, VICTRIX TERA V2 32 EU

|                         |     |
|-------------------------|-----|
| Condensing boiler:      | yes |
| Range rated:            | yes |
| Low-temperature boiler: | no  |
| B1 boiler:              | no  |
| Combination heater:     | yes |

Useful heat output

|  |                |         |
|--|----------------|---------|
| At rated heat output and high-temperature regime (*)         | P <sub>4</sub> | 28,0 kW |
| At 30 % of rated heat output and low-temperature regime (**) | P <sub>1</sub> | 9,4 kW  |

Useful efficiencies (GCV)

|  |          |        |
|--|----------|--------|
| At rated heat output and high-temperature regime (*)         | $\eta_4$ | 87,9 % |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_1$ | 98,8 % |

Useful efficiencies (NCV)

|  |              |         |
|--|--------------|---------|
| At rated heat output and high-temperature regime (*)         | $\eta_{100}$ | 97,6 %  |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_{30}$  | 109,7 % |

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

# Certificate

## KIP-08269

|            |                  |               |  |
|------------|------------------|---------------|--|
| Issue date | 20-04-2026       | Replaces      | KIP-07615  |
| PIN        | 0476DN1192       | Report number | 2011192/7  |
| Module     | B (Type testing) | Scope         | Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992) |

### APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):

VICTRIX TERA V2 38 EU

|                         |     |
|-------------------------|-----|
| Condensing boiler:      | yes |
| Range rated:            | yes |
| Low-temperature boiler: | no  |
| B1 boiler:              | no  |
| Combination heater:     | yes |

Useful heat output

|  |                |         |
|--|----------------|---------|
| At rated heat output and high-temperature regime (*)         | P <sub>4</sub> | 32,0 kW |
| At 30 % of rated heat output and low-temperature regime (**) | P <sub>1</sub> | 10,7 kW |

Useful efficiencies (GCV)

|  |          |        |
|--|----------|--------|
| At rated heat output and high-temperature regime (*)         | $\eta_4$ | 87,9 % |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_1$ | 98,3 % |

Useful efficiencies (NCV)

|  |              |         |
|--|--------------|---------|
| At rated heat output and high-temperature regime (*)         | $\eta_{100}$ | 97,6 %  |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_{30}$  | 109,2 % |

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

# Certificate

## KIP-08269

|            |                  |               |  |
|------------|------------------|---------------|--|
| Issue date | 20-04-2026       | Replaces      | KIP-07615  |
| PIN        | 0476DN1192       | Report number | 2011192/7  |
| Module     | B (Type testing) | Scope         | Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992) |

### APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):

VICTRIX TERA V2 35 PLUS EU

|                         |                   |
|-------------------------|-------------------|
| Condensing boiler:      | yes               |
| Range rated:            | yes               |
| Low-temperature boiler: | no                |
| B1 boiler:              | no                |
| Combination heater:     | no <sup>(1)</sup> |

<sup>(1)</sup> The boiler can be connected to an external tank for domestic hot water production

Useful heat output

|  |                |         |
|--|----------------|---------|
| At rated heat output and high-temperature regime (*)         | P <sub>4</sub> | 32,0 kW |
| At 30 % of rated heat output and low-temperature regime (**) | P <sub>1</sub> | 10,7 kW |

Useful efficiencies (GCV)

|  |          |        |
|--|----------|--------|
| At rated heat output and high-temperature regime (*)         | $\eta_4$ | 87,9 % |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_1$ | 98,3 % |

Useful efficiencies (NCV)

|  |              |         |
|--|--------------|---------|
| At rated heat output and high-temperature regime (*)         | $\eta_{100}$ | 97,6 %  |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_{30}$  | 109,2 % |

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

# Certificate

## KIP-08269

|            |                  |               |  |
|------------|------------------|---------------|--|
| Issue date | 20-04-2026       | Replaces      | KIP-07615  |
| PIN        | 0476DN1192       | Report number | 2011192/7  |
| Module     | B (Type testing) | Scope         | Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992) |

### APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name: **IMMERGAS**

Specifications:

Model(s):

VICTRIX TERA 24 PLUS V2, VICTRIX TERA V2 24 PLUS EU

|                         |                   |
|-------------------------|-------------------|
| Condensing boiler:      | yes               |
| Range rated:            | yes               |
| Low-temperature boiler: | no                |
| B1 boiler:              | no                |
| Combination heater:     | no <sup>(1)</sup> |

<sup>(1)</sup> The boiler can be connected to an external tank for domestic hot water production

Useful heat output

|  |                |         |
|--|----------------|---------|
| At rated heat output and high-temperature regime (*)         | P <sub>4</sub> | 24,0 kW |
| At 30 % of rated heat output and low-temperature regime (**) | P <sub>1</sub> | 8,0 kW  |

Useful efficiencies (GCV)

|  |          |        |
|--|----------|--------|
| At rated heat output and high-temperature regime (*)         | $\eta_4$ | 87,8 % |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_1$ | 98,7 % |

Useful efficiencies (NCV)

|  |              |         |
|--|--------------|---------|
| At rated heat output and high-temperature regime (*)         | $\eta_{100}$ | 97,5 %  |
| At 30 % of rated heat output and low-temperature regime (**) | $\eta_{30}$  | 109,6 % |

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: [info@kiwacermet.it](mailto:info@kiwacermet.it)

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.