



Number	KIP-17404/G	Replaces	KIP-17255/G
Issue date	06-09-2023	Contract number	I 6700
Due date	05-09-2033	Scope	(EU) 2016/426 (9 March 2016)
Report number	2011916/1	Module	B (Type testing)
PIN	0476DN1916		

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the Central heating condensing boiler, type(s):

VICTRIX EXTRA 28, VICTRIX EXTRA 24 PLUS, VICTRIX MAIOR 28, VICTRIX TERA VIP V2, VICTRIX EXTRA 32, VICTRIX MAIOR 32, VICTRIX EXTRA 35, VICTRIX EXTRA 35 PLUS, VICTRIX MAIOR 35, VICTRIX MAIOR 35 PLUS, VICTRIX EXTRA 12 PLUS

Manufacturer

IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041 Brescello (RE) - Italy

Meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard:

EN 15502-1:2021

EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
 Società con socio unico, soggetta all'attività di
 direzione e coordinamento di Kiwa Italia
 Holding Srl

Via Cadriano, 23
 40057 Granarolo dell'Emilia (BO)

Unità locale
 Via Treviso 32/34
 31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

President

Giampiero Belcredi

Digitally signed by: BELCREDI GIAMPIERO

Date: 07/09/2023 12:12:18



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
 Signatory of EA, IAF and ILAC Mutual Recognition Agreements



Number KIP-17404/G **Page** 1 of 1
Issue date 06-09-2023 **Scope** (EU) 2016/426 (9 March 2016)
Due date 05-09-2033 **Module** B (Type testing)
Report number 2011916/1
PIN 0476DN1916

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (GAR)

Brand name:
IMMERGAS

Model name	Appliance types	Heat Input (Hi)	
		CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX EXTRA 28 VICTRIX MAIOR 28 VICTRIX TERA VIP V2	B ₂₃ , B _{23P} , B ₃₃ , B ₅₃ , B _{53P} , C ₁₃ , C ₃₃ ; C ₄₃ , C ₅₃ , C ₆₃ , C ₈₃ , C ₉₃ , C ₍₁₀₎₃ , C ₍₁₂₎₃ , C ₍₁₅₎₃ , C _{13X} , C _{33X} ; C _{43X} , C _{53X} , C _{63X} , C _{83X} , C _{93X}	24,7 – 2,8	28,9 – 2,8
VICTRIX EXTRA 24 PLUS		24,7 – 2,8	⁽¹⁾ 28,9 – 2,8
VICTRIX EXTRA 32 VICTRIX MAIOR 32		28,7 – 2,8	32,9 – 2,8
VICTRIX EXTRA 35 VICTRIX MAIOR 35		32,9 – 2,8	34,0 – 2,8
VICTRIX EXTRA 35 PLUS VICTRIX MAIOR 35 PLUS		32,9 – 2,8	⁽¹⁾ 34,0 – 2,8
VICTRIX EXTRA 12 PLUS		12,2 – 2,0	⁽¹⁾ 12,2 – 2,0

⁽¹⁾ The boiler can be connected to an external tank for the domestic hot water production

Countries:

AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	E(S)	20	Lw	20
H	20; 25	LL	20	Ls	13
EY20	20	L	20	P	30; 37; 50
HY20	20; 25	M	20		

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H₂) when the appliance is set for the reference gas G₂₀.

Remarks: -

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.



Number	KIP-17318/G	Replaces	KIP-17255/E
Issue date	18-05-2023	Contract number	I 6700
Report number	2011916	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
PIN	0476DN1916	Module	B (Type testing)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boiler, type(s):

**VICTRIX EXTRA 28, VICTRIX EXTRA 24 PLUS, VICTRIX MAIOR 28,
VICTRIX TERA VIP V2, VICTRIX EXTRA 32, VICTRIX MAIOR 32,
VICTRIX EXTRA 35, VICTRIX EXTRA 35 PLUS, VICTRIX MAIOR 35,
VICTRIX MAIOR 35 PLUS, VICTRIX EXTRA 12 PLUS**

Manufacturer

IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041 Brescello (RE) - Italy

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard:

EN 15502-1:2021

EN 15502-2-1:2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Kiwa Cermet Italia S.p.A.
Società con socio unico, soggetta all'attività di
direzione e coordinamento di Kiwa Italia
Holding Srl

Via Cadriano, 23
40057 Granarolo dell'Emilia (BO)

Unità locale

Via Treviso 32/34
31020 San Vendemiano (TV)

Tel +39. 0438 411755

Fax +39.0438 22428

E-mail: info@kiwacermet.it

www.kiwa.it

www.kiwacermet.it

GASTEC

President

Giampiero Belcredi

Digitally signed by: BELCREDI GIAMPIERO
Date: 19/05/2023 13:49:29



PRD N° 069B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC
Signatory of EA, IAF and ILAC Mutual Recognition Agreements



Number	KIP-17318/G	Page	1 of 6
Issue date	18-05-2023	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011916	Module	B (Type testing)
PIN	0476DN1916		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):

VICTRIX EXTRA 28
VICTRIX MAIOR 28
VICTRIX TERA VIP V2

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,1	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-17318/G	Page	2 of 6
Issue date	18-05-2023	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011916	Module	B (Type testing)
PIN	0476DN1916		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:
Model(s):
VICTRIX EXTRA 24 PLUS

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production.

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,1	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-17318/G	Page	3 of 6
Issue date	18-05-2023	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011916	Module	B (Type testing)
PIN	0476DN1916		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 32
VICTRIX MAIOR 32

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P_4	28,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P_1	9,5	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,4	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,7	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,6	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-17318/G	Page	4 of 6
Issue date	18-05-2023	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011916	Module	B (Type testing)
PIN	0476DN1916		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 35
VICTRIX MAIOR 35

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P_4	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P_1	10,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-17318/G	Page	5 of 6
Issue date	18-05-2023	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011916	Module	B (Type testing)
PIN	0476DN1916		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 35 PLUS
VICTRIX MAIOR 35 PLUS

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production.

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,5	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Number	KIP-17318/G	Page	6 of 6
Issue date	18-05-2023	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)
Report number	2011916	Module	B (Type testing)
PIN	0476DN1916		

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:
Model(s):
VICTRIX EXTRA 12 PLUS

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	no ⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production.

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	12,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	4,0	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η ₄	88,7	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η ₁₀₀	98,5	%
At 30 % of rated heat output and low-temperature regime (**)	η ₃₀	109,7	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)

(NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia. Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.