

Certificate KIP-08295



Issue date	26-05-2026	Replaces	KIP-17404/G
PIN	0476DN1916	Report number	2011916/2
Valid from	26-05-2026	Due date	25-05-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

EU TYPE-EXAMINATION CERTIFICATE (GAR)

Kiwa Cermet Italia declares that the central heating condensing boiler, type(s):

**VICTRIX EXTRA 28, VICTRIX MAIOR 28, VICTRIX TERA VIP V2, VICTRIX EXTRA 24 PLUS,
VICTRIX EXTRA 32, VICTRIX MAIOR 32, VICTRIX EXTRA 35, VICTRIX MAIOR 35,
VICTRIX EXTRA 35 PLUS, VICTRIX MAIOR 35 PLUS, VICTRIX EXTRA 12 PLUS**

Manufacturer

IMMERGAS S.p.A.

Via Cisa Ligure, 95

42041, Brescello (RE), Italy

Meet the essential requirements as described in the

Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Reference standard:

EN 15502-1:2021+A1:2023

EN 15502-2-1:2022+A1:2023

CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.a.

Product Certification and Testing Director

Luigi Rindone

Firmato digitalmente da:

Luigi Rindone

Luigi Rindone

Certificate

KIP-08295

Issue date	26-05-2026	Replaces	KIP-17404/G
PIN	0476DN1916	Report number	2011916/2
Valid from	26-05-2026	Due date	25-05-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

APPENDIX TO EU TYPE- EXAMINATION CERTIFICATE (GAR)

Brand name:

IMMERGAS

Types:

Model name	Heat Input (Hi)	
	CH Max – Min (kW)	DHW Max – Min (kW)
VICTRIX EXTRA 28 VICTRIX MAIOR 28 VICTRIX TERA VIP V2	24,7 – 2,8	28,9 – 2,8
VICTRIX EXTRA 24 PLUS	24,7 – 2,8	⁽¹⁾ 28,9 – 2,8
VICTRIX EXTRA 32 VICTRIX MAIOR 32	28,7 – 2,8	32,9 – 2,8
VICTRIX EXTRA 35 VICTRIX MAIOR 35	32,9 – 2,8	34,0 – 2,8
VICTRIX EXTRA 35 PLUS VICTRIX MAIOR 35 PLUS	32,9 – 2,8	⁽¹⁾ 34,0 – 2,8
VICTRIX EXTRA 12 PLUS	12,2 – 2,0	⁽¹⁾ 12,2 – 2,0

⁽¹⁾ The boiler can be connected to an external tank for the domestic hot water production

Appliance types:

B₂₃, B_{23P}, B₃₃, B₅₃, B_{53P},
C₁₃, C₃₃; C₄₃, C₅₃, C₆₃, C₈₃, C₉₃, C₍₁₀₎₃, C₍₁₂₎₃, C₍₁₅₎₃
C_{13X}, C_{33X}; C_{43X}, C_{53X}, C_{63X}, C_{83X}, C_{93X}

Countries:

AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GR, HR, HU, IE, IT, LT, LU, LV, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Certificate

KIP-08295

Issue date	26-05-2026	Replaces	KIP-17404/G
PIN	0476DN1916	Report number	2011916/2
Valid from	26-05-2026	Due date	25-05-2036
Module	B (Type testing)	Scope	Reg. (EU) 2016/426 (9 March 2016)

APPENDIX TO EU TYPE- EXAMINATION CERTIFICATE (GAR)

Gas groups:

Group	mbar	Group	mbar	Group	mbar
E	20	E(S)	20	Lw	20
H	20; 25	L	20	Ls	13
EY20	20	M	20	P	30; 37; 50
HY20	20; 25				

The above gas groups can be combined according to the standard EN437:2021 and national situation of countries.

Note: Suffix "Y20" means that the appliances are suitable for the use of natural gas of the indicated gas group, mixed with hydrogen resulting in a gas mixture containing up to 20% of Hydrogen gas (H2) when the appliance is set for the reference gas G20.

Remarks: -

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it
 This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.
 Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.

Certificate KIP-08296



Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

EC TYPE-EXAMINATION CERTIFICATE (BED/R813)

Kiwa Cermet Italia, notified body for council Directive 92/42/EC, hereby declares that the central heating condensing boiler, type(s):

VICTRIX EXTRA 28, VICTRIX MAIOR 28, VICTRIX TERA VIP V2, VICTRIX EXTRA 24 PLUS, VICTRIX EXTRA 32, VICTRIX MAIOR 32, VICTRIX EXTRA 35, VICTRIX MAIOR 35, VICTRIX EXTRA 35 PLUS, VICTRIX MAIOR 35 PLUS, VICTRIX EXTRA 12 PLUS

Manufacturer
IMMERGAS S.p.A.
Via Cisa Ligure, 95
42041, Brescello (RE), Italy

Meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and as described in the **Directive 92/42/EEC on efficiency requirements.**

Reference standard:
EN 15502-1:2021+A1:2023
EN 15502-2-1:2022+A1:2023
CEN/TS 15502-3-1:2024

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

Kiwa Cermet Italia S.p.a.
Product Certification and Testing Director
Luigi Rindone

Firmato digitalmente da:
Luigi Rindone

Certificate

KIP-08296

Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 28,
VICTRIX MAIOR 28,
VICTRIX TERA VIP V2

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,1	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Certificate

KIP-08296

Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:
Model(s):
VICTRIX EXTRA 24 PLUS

Condensing boiler: yes
Range rated: yes
Low-temperature boiler: no
B1 boiler: no
Combination heater: no⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	24,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	8,1	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Certificate

KIP-08296

Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 32,
VICTRIX MAIOR 32

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	28,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	9,5	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,4	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,7	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,6	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Certificate

KIP-08296

Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 35,
VICTRIX MAIOR 35

Condensing boiler:	yes
Range rated:	yes
Low-temperature boiler:	no
B1 boiler:	no
Combination heater:	yes

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Certificate

KIP-08296

Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:

Model(s):
VICTRIX EXTRA 35 PLUS,
VICTRIX MAIOR 35 PLUS

Condensing boiler: yes
Range rated: yes
Low-temperature boiler: no
B1 boiler: no
Combination heater: no⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	32,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	10,8	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,2	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,6	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,0	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,5	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

Certificate

KIP-08296

Issue date	26-05-2026	Replaces	KIP-17318/G
PIN	0476DN1916	Report number	2011916/2
Module	B (Type testing)	Scope	Art.4 of No.813/2013 (2-8-2013) and 92/42/EEC (21-05-1992)

APPENDIX TO EU TYPE-EXAMINATION CERTIFICATE (BED/R813)

Brand name:
IMMERGAS

Specifications:
Model(s):
VICTRIX EXTRA 12 PLUS

Condensing boiler: yes
Range rated: yes
Low-temperature boiler: no
B1 boiler: no
Combination heater: no⁽¹⁾

⁽¹⁾ The boiler can be connected to an external tank for domestic hot water production

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	12,0	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	4,0	kW
Useful efficiencies (GCV)			
At rated heat output and high-temperature regime (*)	η_4	88,7	%
At 30 % of rated heat output and low-temperature regime (**)	η_1	98,8	%
Useful efficiencies (NCV)			
At rated heat output and high-temperature regime (*)	η_{100}	98,5	%
At 30 % of rated heat output and low-temperature regime (**)	η_{30}	109,7	%

- (*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.
- (**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).
- (GCV) Calculated values are based on Gross calorific value (reference conditions:15 °C, 1013,25 mbar)
- (NCV) Calculated values are based on Net calorific value (reference conditions:15 °C, 1013,25 mbar)

The validity of this certificate can be verified on request at the following e-mail address: info@kiwacermet.it

This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Any total or partial reproduction of this document in any form, without Kiwa Cermet Italia express authorization, is prohibited.