

EU TYPE-EXAMINATION CERTIFICATE (MODULE B) REGULATION (EU) 2016/426

This is to certify that the listed appliances have been examined and found to comply with the essential requirements listed in the **Regulation (EU) 2016/426** of the European Parliament and of the council of 9 March 2016 on appliances burning gaseous fuels (Annex I).

To demonstrate full compliance with the Regulation (EU) 2016/426, a "Conformity to Type" Module C2 or D or E or F is required.

Manufacturer: Immergas S.p.A.

Via Cisa Ligure, 95
42041 Brescello (RE)
Italy

Trademark: IMMERGAS

Product Type: Gas-fired floor-standing condensing boiler

Models: HERCULES 25, HERCULES SOLAR 25, HERCULES MINI 35,
HERCULES 35, HERCULES 35 ABT

Certificate N°: ITS-2575-GAR-2438199-R1

PIN: 2575DP38199

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200038199UDI-GCE-RCE-R1

This certificate cancels and replaces the previous one.

Certificate first issue date:


02 October 2024

Certificate current issue date:

17 July 2026

Certificate expiration date:

01 October 2034



Michael Albert Gandin

Certification Manager
Intertek Italia SpA (NB 2575)



00151

Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned from the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

PRODUCT DESCRIPTION

PRODUCT TYPE:	Gas-fired floor-standing condensing boiler
MODELS:	HERCULES 25, HERCULES SOLAR 25, HERCULES MINI 35, HERCULES 35, HERCULES 35 ABT
STANDARD(S):	EN 15502-1:2021 + AC:2022, EN 15502-2-1:2022 + A1:2023/AC:2024, CEN/TS 15502-3-1:2024, UNI/TS 11854:2022
SPECIAL REMARKS:	-
APPLIANCES TYPE:	B ₂₃ , B _{23P} , B ₃₃ , B ₅₃ , B _{53P} , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₆₃ , C ₈₃ , C ₉₃ , C ₍₁₀₎₃ *, C ₍₁₂₎₃ *, C ₍₁₅₎₃ *, C _{13X} , C _{33X} , C _{43X} , C _{53X} , C _{63X} , C _{83X} , C _{93X} , C _{(10)3X} *, C _{(12)3X} *, C _{(15)3X} *
GAS CATEGORIES:	* = these appliance typologies are NOT available for gas category 3P (G31) I _{2H} , I _{2HY20} , I _{2HM} , I _{2HY20M} , I _{2E} , I _{2EY20} , I _{2E(S)} , I _{2E(R)} , I _{2ELwLs} , I _{2EY20LwLs} , I _{2NY20Z192} , I _{3P} , II _{2H3P} , II _{2HY203P} , II _{2HM3P} , II _{2HY20M3P} , II _{2E3P} , II _{2EY203P} , II _{2E(S)3P} , II _{2E(R)3P} , II _{2ELwLs3P} , II _{2EY20LwLs3P} , II _{2NY20Z1923P}

DETAILS FOR GAS GROUPS AND SUPPLY PRESSURES:

GROUP	NOMINAL PRESSURE	GROUP	NOMINAL PRESSURE	GROUP	NOMINAL PRESSURE
H	20/25 mbar	E(S)	20 mbar	P	30 mbar
HY20	20/25 mbar ⁽¹⁾	E(R)	20 mbar	P	37 mbar
E	20 mbar	Lw	20 mbar	P	50 mbar
EY20 ⁽¹⁾	20 mbar ⁽¹⁾	Ls	13 mbar		
M	20 mbar	NY20Z192	20/25 mbar ⁽¹⁾⁽²⁾		

⁽¹⁾ Suffix Y20 indicates gas group(s) not yet introduced in EN 437:2021 and based on a gas blend of Methan/Hydrogen resulting in a gas mixture with max 20% amount of H2 when the appliance is set for the reference gas G20

⁽²⁾ Suffix Z192 indicates a Wobbe range between 35,5 MJ/m3 and 54,69 MJ/m3 (Wobbe bandwidth of 19,2 MJ/m3).

REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PROJECT NO.	REPORT NO.	REASON FOR REVISION
02/10/2024	M.A. Gandin	38199	200038199UDI-GCE	R0: First issue
14/07/2026	M.A. Gandin	47347	200038199UDI-GCE-RCE-R5	R1: standard updating, introduction of alternative components and introduction of new gas categories

EC TYPE-EXAMINATION CERTIFICATE (MODULE B) DIRECTIVE 92/42/EEC

This is to certify that, with reference to the Council **Directive 92/42/EEC** of 21 May 1992 on efficiency requirements for new hot-water boilers fired with liquid or gaseous fuels and according to article 4 of commission regulation (EU) No. 813/2013, the appliances listed have achieved the full and part load efficiencies written on Annex 1.

To demonstrate full compliance with the Directive 92/42/EEC, a "Conformity to type" Module C or D or E is required.

Manufacturer: Immergas S.p.A.

Via Cisa Ligure, 95
42041 Brescello (RE)
Italy

Trademark: IMMERGAS

Product Type: Gas-fired floor-standing condensing boiler

Models: HERCULES 25, HERCULES SOLAR 25, HERCULES MINI 35,
HERCULES 35, HERCULES 35 ABT

Certificate N°: ITS-2575-BED-2438199

PIN: 2575DP38199

Standard(s): EN 15502-1:2021+A1:2023, EN 15502-2-1:2022+A1:2023

This certificate only relates to those products detailed in the following Test Reports:


Report Number: 200038199UDI-GCE

Certificate Issue date:

02 October 2024

Certificate Expiry date:

01 October 2034



Michael Albert Gandin

Certification Manager
Intertek Italia SpA (NB 2575)



PRD N° 277B

Membro degli Accordi di Mutuo
Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC
Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

ANNEX 1

Models:			
	HERCULES 25, HERCULES SOLAR 25	HERCULES MINI 35, HERCULES 35, HERCULES 35 ABT	
η_{100}	97,4 %	97,3 %	
η_{30}	109,9 %	109,7 %	
η_4	87,7 %	87,6 %	
η_1	99 %	98,8 %	
P_4	20,2 kW	28,2 kW	
P_1	6,9 kW	9,5 kW	
C.Heater	Yes	Yes	
B ₁ Boiler	No	No	
Type of boiler:	Condensing	Condensing	
Range rated	Yes	Yes	

Note: η_{100} = At rated heat output and high-temperature regime - NCV (*) - EN 15502-1:2021+A1:2023, clause 9.4.3: "the useful efficiency in % at nominal heat input Q_n or for range rated boilers at the arithmetic mean of the maximum and minimum heat input"

η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**) - EN 15052-1:2021+A1:2023, clause 9.4.4: "the useful efficiency in % at 30 % of the nominal heat input Q_n or for range rated boilers at 30 % of the arithmetic mean of the maximum and minimum heat input"

η_4 = At rated heat output and high-temperature regime - GCV (*) - EN 15502-1:2021+A1:2023, clause 9.4.3: "the useful efficiency (GCV) at rated heat output"

η_1 = At 30 % of rated heat output and low-temperature regime - GCV (**) - EN 15052-1:2021+A1:2023, clause 9.4.4: "the useful efficiency at 30 % heat output"

P_4 = At rated heat output and high-temperature regime (*)

P_1 = At 30 % of rated heat output and low-temperature regime (**)

C.Heater = Combination Heater (Yes = with domestic hot water production / No = Heating system only)

B₁ Boiler = Type B₁ according to CEN/TR 1749:2020

Type of boiler: "Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temp. means for condensing boilers 30 °C, for low-temp. boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(n.t. = not tested; n.a. = not applicable)

REVISION AND COMMENTS

DD/MM/YYYY	AMENDED BY	PROJECT NO.	REPORT NO.	REASON FOR REVISION
02/10/2024	M.A. Gandin	38199	200038199UDI-GCE	R0: First issue